



Duct Opening Reducer

No. 4 Duct to No. 2 Duct

Cat. No. 275SR/275SL

INSTALLATION INSTRUCTIONS

Walker® electrical systems conform to and should be properly grounded in compliance with requirements of the current National Electrical Code or codes administered by local authorities.

All electrical products may represent a possible shock or fire hazard if improperly installed or used. Walker electrical products may bear the mark as UL Listed and/or Classified and should be installed in conformance with current local and/or the National Electrical Code.

1. Position adaptor at angle shown relative to opening.
2. Insert end of narrow leg into box opening and rotate part toward opening.
3. Complete installation by striking part until fully inserted into opening.
4. Install duct step utilizing the double backed adhesive tape.
5. Insert No. 2 duct into opening until end of duct is against duct stop.
6. Insert legs of ground clip into the triple slot opening and drive in with a hammer until fully seated in place.

