



## DEVICES ARE PRESET FOR PLUG n' $GO^{TM}$ OPERATION, ADJUSTMENT IS OPTIONAL.

Sequence of Operation: In this configuration The LMRC-102 defaults to bi-level automatic-on/automatic-off. Load (a) turns on automatically and load (b) defaults to manual-on control; both loads turn automatically off. The LMLS-400 monitors the ambient light in the controlled space and works with the room controller(s) to maintain the design light level. For full operational details, adjustments and more features of the product, see the DLM System Installation Guide at www.wattstopper.com

*WattStopper*® 800-879-8585

Title

Large Office w/Daylighting

None Drawing# 90-952

Date 5/17/10

0