

GENERAL NOTES:

- 1. EMERGENCY LIGHTING CONNECTED THROUGH THE ELCU IS CONTROLLED WITH THE NORMAL LIGHTING FOR THE DESIGNATED AREA.
- 2. EMERGENCY LIGHTING TURNS ON AUTOMATICALLY UPON LOSS OF POWER IN THE SWITCHED NORMAL CIRCUIT REGARDLESS OF THE STATE OF THE RELAY.
- 3. ALL COMPONENTS IN THE EMERGENCY PANEL SECTION COMPLY WITH UL924 FOR USE IN EMERGENCY LIGHTING CIRCUITS.
- 4. VERIFY THAT WIRING FOR NORMAL LIGHTING CIRCUITS IS NOT ROUTED THROUGH THE EMERGENCY SECTION OF THE PANEL.

Watt Stopper/Legrand 800-879-8585

Title

ELCU in LI Relay Panel

Scale	Drawing#	Date	Rev.
None	61-800	04/08/08	1