Pass and Seymour
Hospital-Grade 15A Self-Test Duplex GFCI, Ivory
Part No. 1597HGI

Conducts an automatic test every three seconds, ensuring it's always ready to protect. If the device fails the test, the indicator light flashes to signal that the GFCI should be replaced. It also has our proven SafeLock&trade- Protection feature: if critical components are damaged and protection is lost, power to the receptacle is disconnected.

Specifications

General Info

Color	Ivory	UPC Number	785007036084
Country Of Origin	China	Product Line	Pass & Seymour
Application Sector	Residential/Commercial	Standard	cULus, UL Listed, FSUL

Listing Agencies / 3rd Party Agencies

cULus Listed	Yes

Additional Information

Product Environmental Profile	Yes

Technical Information

Number of Poles	Double Pole	Voltage	125 V
Trip Range	4 to 6 mA	Connection	Back and Side Wire
Frequency Rating	60 Hz	Interrupt Rating	4 A
Environmental Conditions	95% Humidity, UL 94 V2		