

LEGEND

2	LMUC-100-2
LMRC 101	LMRC-101
LM 101	LMSW-101
J	Junction Box
F	Fan
	CAT5e
	Line Voltage Wiring

DEVICES ARE PRESET FOR PLUG n' GO™ OPERATION, ADJUSTMENT IS OPTIONAL.

Sequence of Operation: In this configuration The LMRC–101 defaults to manual–on/automatic–off. The LMRC–101 controlling the fan defaults to manual–on/automatic–off. In this scenario, the room controllers and sensors require **Push n' Learn™** custom configuration. Each restroom will have independant control of the lighting but will share control of the fan. For full operational details, adjustments and more features of the product, see the DLM System Installation Guide at www.wattstopper.com

WattStopper®
800-879-8585

Title			
Restroom w/ Switch and Fan Control			
Scale	Drawing#	Date	Rev.
None	90–932	05/17/10	0